

DISCOUNT LEVEL A

Model	Duration	Battery	Lumens	Light source	€
Non-maintained:					
Lisu-B N	1 h	Ni-Mh	110	LMS _{LED}	-----
Lisu-B 2N	2 h	Ni-Mh	110	LMS _{LED}	-----
Lisu-B 3N	3 h	Ni-Mh	110	LMS _{LED}	-----

Model	Duration	Battery	Lumens	Light source	€
Maintained: (1)					
			Emerg./Lum.		
Lisu-B P	1 h	Ni-Mh	110	LMS _{LED}	-----
Lisu-B 2P	2 h	Ni-Mh	110	LMS _{LED}	-----
Lisu-B 3P	3 h	Ni-Mh	110	LMS _{LED}	-----

Lisu Pennant A | Specifically for Self-test

Lisu Pennant TCA | Specifically for Self-test and DaisaTest System.

Includes microprocessor for Self-test mode operation **A** or DaisaTest centralised management system **TCA**
 Fill out the reference with **A** or **TCA** depending on the model. TEV test control unit for Lisu-B TCA: See page 117
 Example of order: Lisu-B N A / Lisu-B N TCA

Model	Duration	Battery	Lumens	Light source	A €	TCA €
Non-maintained:						
Lisu-B N <input type="checkbox"/>	1 h	Ni-Mh	110	LMS _{LED}	-----	-----
Lisu-B 2N <input type="checkbox"/>	2 h	Ni-Mh	110	LMS _{LED}	-----	-----
Lisu-B 3N <input type="checkbox"/>	3 h	Ni-Mh	110	LMS _{LED}	-----	-----

Model	Duration	Battery	Lumens	Light source	A €	TCA €
Maintained: (1)						
			Emerg./Lum.			
Lisu-B P <input type="checkbox"/>	1 h	Ni-Mh	110	LMS _{LED}	-----	-----
Lisu-B 2P <input type="checkbox"/>	2 h	Ni-Mh	110	LMS _{LED}	-----	-----
Lisu-B 3P <input type="checkbox"/>	3 h	Ni-Mh	110	LMS _{LED}	-----	-----

Lisu Pennant DALI | Specifically for DALI System

Models for the DALI system are available. By arrangement with the factory.

Lisu Pennant Luminaire | DOES NOT INCLUDE BATTERY

Luminaire specific function

Model	Power supply	Lumens	Light source	€
Lisu-B L	See power supply	110	LMS _{LED}	-----

Finishes

Finish of	Description	Marking	Incr. €
Colour	White (as standard)	-----	-----
	Dark metallic grey	(GR)	-----
	Silver grey	(RAL9006)	-----
Power supply: Self-contained	220-230V 50/60Hz	-----	-----
	110-127V 50/60Hz	(110-127V)	-----
Luminaires	110-240V 50/60Hz, 170-320V DC	-----	-----
	24V 50/60Hz, 18-30V DC	(24V)	-----

RTD...	Description	Resulting flux
	This device has dual light output (two diffusers). The emergency sign is factory-mounted on the diffuser RTD: 254x127 mm, RTD1336: 127x127 mm Complies with the UNE-EN 1838 and EN ISO 7010 standards Customised signs and emergency signs supplied to order.	25% -----

Description	Marking	Description	Marking	Description	Marking
	(RTD1328)		(RTD1331)		(RTD1334)
	(RTD1329)		(RTD1332)		(RTD1335)
	(RTD1330)		(RTD1333)		(RTD1336)

Operation, shared data and notes:

The emergency luminaires equipped with Ni-Mh battery technology include a pulse-load microprocessing system that enables an important reduction of energy consumption.

(1) The maintained models CANNOT be switched off when mains power is available, except for TCA models that can be switched off through the DaisaTest centralised management system.

Features plug & play and anchoring system.

Built to the EN 60598-2-22 (IEC 60598-2-22) standard. Protection rating: IP22 IK04.

Lisu Pennant
Lisu-B

