

TEV-200

Code: TEV0200000




TEV Control unit

Description:

Rectangular polycarbonate casing with status indicators and control buttons for the device on the front panel. Provided with serial ports that allow communication between the luminaries, the control unit and a computer. Designed to be installed on a symmetrical DIN 46277/3, EN 50022 rail of an electrical panel, taking up a width of 8 single magneto-thermal switches (141 mm). SBT-200 bus switches not needed. The installation is controlled by a local or remote computer. Functions: - Management of communication between the control computer and Daisatest system devices. Communication with the control computer can be performed using RS232 or ETHERNET connection. - Detects and reports main bus failures (short circuit and leakage) via indicator lights. - Management of functionality and autonomy testing, which must be made by self-contained luminaires, even when the PC is switched off or disconnected. - The port labelled AUX allows all of the light fittings connected to the Bus to be switched on, useful when connected to a central fire alarm system. Connection of MBAT 12-11 battery pack: - Operation is maintained in absence of power supply (independence of more than 1 hour). - Performs remote control functions: stand-by and restart. - There is a TEST-BUS button to facilitate set-up and checking of the bus.

Characteristics:

Format: TEV Control unit
No. of appliances commanded: 200
BUS: EV-TAM
Anchoring: Symmetrical DIN 46277/3 rail



TEV Control unit

**Daisalux reserves the right to change, update or remove the information contained in this document without prior warning.
The selected finishes may not coincide with the displayed images.